ROUND WATER SURVEY REPORT

OPEN WELL / BOREWELL
DATA OF SURVEY

Name of the Party : BBMP Ward No. 9

Location of the Site : Anjanadri Layout.

Area of the land : Road

INVESTIGATION REPORT

GEOLOGY OF THE AREA : Clayey / Granite Gneiss

Recommended Site for drilling : W1

Total depth to be drilled : 1000-1200'

Approx. casing pipe required : 130L-40'

No. of water bearing Zones : ~4~

No. of favorable spots marked : -1-

Qty. of water expected : 2"-3"

Method of survey carried out : Geophysical

Remarks : 6½" dia drilled at W1

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

T.O. : Terms & Conditions

BOREWELL SITE PLAN



Assistant Executive En
Vidyaranyapura Sub D
BBMP, Bangalore -

GROUND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
DATA OF SURVEY

a) Name of the Party : BBMP Engineering

b) Location of the Site : Thirdha Vidyapeeta

c) Area of the land : RO Road

INVESTIGATION REPORT

1) GEOLOGY OF THE AREA : clayey, gritic, etc Laterite.

2) Recommended Site for drilling : W1

3) Total depth to be drilled : 1000

4) Approx. casing pipe required : 130'-140'

5) No. of water bearing Zones : -4-

6) No. of favorable spots marked : -1-

7) Qty. of water expected : 2½"-3"

8) Method of survey carried out : Ground

9) Remarks : 6½" Dia bellow W1

320'-1000'

P.T.O. : *Terms & Conditions*

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



Assistant Executive
Vidyaranyapura Sub
BBMP, Bangalore

ROUND WATER SURVEY REPORT

OPEN WELL / BOREWELL
DATA OF SURVEY

Name of the Party : BBMP Wards 19

Location of the Site : Vidyapur / Thidlu

Area of the land : Ward (Gadina Gollara)

INVESTIGATION REPORT

) GEOLOGY OF THE AREA : Granitic Gneiss.

) Recommended Site for drilling : W1

) Total depth to be drilled : 800-1000'

) Approx. casing pipe required : 130-140'

) No. of water bearing Zones : - 4 -

) No. of favorable spots marked : - 1 -

) Qty. of water expected : 2 to 3 lit

) Method of survey carried out : Geophysical

) Remarks : 6½" dia Bore well at W1

360'-1000' (Casing)

P.T.O. : Terms & Conditions

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



Assistant Executive E
Vidyaranyapura Sub
BBMP, Bangalore

OUND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
DATA ~~OF~~ SURVEY

ame of the Party : BBMP Mundakara No 9

ocation of the Site : Anganadi Kendra, KG Nagara

ea of the land : Rd Pland-

INVESTIGATION REPORT

EOLOGY OF THE AREA : Clayey & gritty, weathering

commended Site for drilling : W1

tal depth to be drilled : 1000-1200'

pprox. casing pipe required : 160-170'

. of water bearing Zones : 4-

. of favorable spots marked : 1

y. of water expected : 2 L 3"

ethod of survey carried out : Surface land

marks : 6½ dia Bore well at W1

400-1000'

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

. : *Terms & Conditions*

BOREWELL SITE PLAN



Assistant Executive Engin
Vidyaranyapura Sub Divis
BBMP, Bangalore - 97

OUND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
~~DATA~~ OF SURVEY

Name of the Party : BBMP Mudnwi 10

Location of the Site : Anjanappa Layout
Doddabommasandra.

Area of the land :

INVESTIGATION REPORT

GEOLOGY OF THE AREA : clayey, gritte with limestone

Recommended Site for drilling : W1

Total depth to be drilled : 1080-1200'

Approx. casing pipe required : 160-180'

No. of water bearing Zones : — 4 —

No. of favorable spots marked : — 1 —

Qty. of water expected : 2" - 3"

Method of survey carried out : Geophysical

Remarks : 6½" dia drilled-W1

460 - 1150'

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

T.O. : Terms & Conditions

BOREWELL SITE PLAN



AE, W10.

Assistant Executive Engine
Vidyaranyapura Sub Divisi
BBMP, Bangalore - 97

UND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
DATA OF SURVEY

ne of the Party : BBMP-Ward No: 11

ation of the Site : MS Palya Primary Health Centre

a of the land : R.O. Plant

INVESTIGATION REPORT

COLOGY OF THE AREA : Sandy clay, clayey, granite stone

ommended Site for drilling : W1,

l depth to be drilled : 1000-1200'

rox. casing pipe required : 130'-140'

of water bearing Zones : - 4 -

of favorable spots marked : - 1 -

of water expected : 2"-3"

hod of survey carried out : Geophysical

arks : 6"1/2" diameter - W1

Sandy clay 460'-1150'

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

: *Terms & Conditions*

BOREWELL SITE PLAN